

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/AGR/07/25/342

Dated: 19/07/2025

It is certified that an inspection team headed by Er. Mahit Kumar (Name of Officers with designation) from U.P. Jal Nigam (Rural), Agra, inspected the **Glorious Public School, Guru Ramdas Nagar, Kakretha, Agra** (Name & Address of the school) on 16/07/2025 (date of inspection) and on the basis of Water Test Report(Attached) bearing no UPJN/AGR/25/07/342 dated 19/07/2025 of Regional Level Water Analysis Laboratory(UP JAL NIGAM) certified that the **Glorious Public School, Guru Ramdas Nagar, Kakretha, Agra** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one year from issue date

Signature with Seal:

Name: Er. Mahit Kumar

Designation: A.E. खण्ड कार्यालय

Name & Address of the Office/Department: उपग्राम जल निगम (ग्रामीण)
अगरा (Rural), Agra

To

Glorious Public School,

Guru Ramdas Nagar, Kakretha,

Agra

Amite

19/07/2025

(Lab chemist)

* Sample collected by the poonam Sharma.

Amite



Regional Water Testing Laboratory
Address: 4/4 Sanjay Palace U.P. JalNigam(Rural) Agra, 282002



TEST REPORT					
Report No:	UPJN/AGR/07/25/342	Issue Date:	19/07/2025	Page No	2
Customer Details					
Office Name and Address	Principal Glorious Public School Guru Ramdas Nagar, Kakretha, Agra				
Ref Letter No & Date	Zeero& 15/07/2025				
Basic details of sample					
District	Agra	Block	Agra		
Gram Panchayat	--	Village/city	Agra		
Water Source	R.O Water	Location	Glorious Public School		
Quantity of Sample	1 Lt	Sample No.	01		
Receiving Date	15/07/2025	Date of Collection	14/07/2025		
Sample Depositor	Poonam Sharma	S. Collector	14/07/2025		
		Sampling Method	As per IS 17614: Part 1: 2021		
Analysis Start Date	16/07/2025	Analysis Completion Date:	17/07/2025		
Technical Data of Analysis					
S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	8.02	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity mg/L	1.24	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	106	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	0.296	1	1.5	APHA 23 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	12	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	36	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	28	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	Nill	1	1	APHA 23 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	02	200	400	APHA 23 rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium mg/L	04	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	1.94	30	100	IS 3025 (Part 46):1994(Volumetric Method)
12	Color (Hazen)	-	5	15	IS 3025(Part 4)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)
14	Nitrate (mg/l)	Nill	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)



Regional Water Testing Laboratory

Address: 4/4 Sanjay Palace U.P. JalNigam(Rural) Agra, 282002



Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Reviewed By


(Amita Devi)
(Deputy Quality Manager)


(Amita Devi)
Authorized Signatory:
Testing Laboratory in charge

Laboratory Contact details
Email- ZlaupjnR@gmail.com



-----End of Report-----